

DELHI DEVELOPMENT AUTHORITY

OFFICE OF THE EXECUTIVE ENGINEER (EI.)

ELECTRICAL DIVISION.8, 21ST FLOOR, VIKAS MINAR

Ph:- 011- 23370632, 9899516333 (M)

E-MAIL ID:- eeeld8@gmail.com

NEW DELHI-110002

No. F 6 (15)/EE/EI. Divn.8/DDA/ 38

Dated:- 8-4-16

MINUTES OF MEETINGS

Subject:- Pre-bid meeting for the following works of:-


NIT No. 62/EE(E)/ELD.8/DDA/2015-16


**Name of Work : C/O 288 EWS Houses at vacant pocket behind Ramgarh Colony, Jahangirpuri.
SH - Supplying, installation, testing & commissioning of Down comer fire fighting system.**


Pre bid meeting was held in the office of EE (EI.)/ELD.8/DDA on 08.04.2016 at 2.00 PM. The list of participant is enclosed.

Discussions held and the following discrepancies was pointed out by the representative of the agencies. Thus the following addition/alteration is required in the NIT:-

1. **Item No. 1.1- Cement concrete block** as support stand deleted in description of item.
2. **Item No. 1.2- IS 5312** is deleted and should be as per relevant IS Code in description of item.
3. **Item No. 2.1-** Split casing is deleted in description of item.
4. **Item No. 2.90** –Cabinet of size **900 mm X 750 mm X 500 mm** may be read in place of 900 mm X 600 mm X 500 mm (Nominal) in description of item
5. **Item No. 3.20-** May be read as **6 Kg capacity** in place of 5 Kg capacity in description of item.
6. In the list of approved makes **KIRLOSKAR** is added at sr. No. 5 (Butterfly valve).
7. Makes of item No.6 (Steel pipe flange) under list of approved makes stand deleted.
8. **GETECH/OMEX/LIFEGUARD** make is added in the existing list of approved makes at sr. no. 11 of (Hose Reel Drum with GM Nozzle).


 08/04/2016
AE(P)/El. Divn.8


AE(EI.)-IV/ELD.8


EE (EI.) /ELD.8

Copy to:-

1. SE (EI.)-2 for kind information please.
2. All Participants.
3. This M.O.M. shall form part of agreement.
4. M/s Fire Cool Engineers.


EE (EI.) /ELD.8