

**OFFICE OF THE SUPERINTENDING ENGINEER (E)**  
**ELECTRICAL CIRCLE-3, DDA, VIKAS MINAR,**  
**NEW DELHI.**

No. F68(9)pt.II/EE(P)/EC3/DDA/2015-16/ 04

Dt 20.01.2016

**MINUTES OF MEETING**

Name of work:- M/o Various scheme under N.A.-II, East Zone.

SH- S/I/T/C of street lights at I.P.Extn. to Mandawali Fazalpur.  
NIT No. 33/EE/ELD-1/DDA/2015-16  
Estimated cost:- ₹ 58,84,450/-

Pre-bid meeting was held for the above work on 20.01.2016 at 12:30 PM in the chamber of SE (Elect.)-3 wherein following officers of DDA were present.

9. Sh. P.K. Solanki, SE (Elect.)-3 In Chair
10. Sh.M.C Saxena, EE(E)Plg./EC-3
11. Sh. Bhagwan Singh EE(E)/ELD-1
12. Sh. S. K. Garg, AE(E)/ELD-1

Name of Contractor-



7. Sh Anil Goel , M/s Goel Electricals
8. Sh Nikhil Kalani, M/s N.K.Engg. works
9. Sh Saranbir Singh, M/s Bajaj Electricals

After due deliberation & discussion, during the meeting the following changes have been decided.

11. Outer diameter of the single arm bracket shall be suitable for fixing the LED fitting instead of 60.3 mm Dia mentioned in the drawing of NIT.
12. On the request of contractors in the pre-bid meeting, in the list of approved makes, the makes of LED street light fitting shall be reads as:-Phillips/ Schreder/ Osram/ Surya/Crompton/Bajaj instead of Phillips/Schreder/Osram/Surya/Crompton mentioned in NIT.
13. In the technical specification at Sr.No. 2 (i), the lumens/watt. (System Efficacy) as per LM 79 report (luminaire Efficacy) shall be more than 100 lumens/watt. instead of  $\geq 85$  lumens/watt.
14. In the technical specification at Sr. No. 2 (ii), Surge protection shall be read as 4 KV internal/10 KV using external configuration protection instead of 4 KVA internal/10 KVA using external configuration protection.

15. In the schedule of work, item no5.02 of HDPE pipe shall be read as 110 mm outer dia nominal size instead of 120 mm outer dia nominal size.

This letter shall be part of the tender. Therefore, **this letter duly stamped and signed by the tenderers in lieu of their acceptance, shall be submitted by all tenderers failing which their tenders will not be opened. This MOM shall be uploaded by EE/ELD-1 to DDA website.**

No.	Designation/Company/Post	Phone No.	Signature
1	AE(E)ELD-1		
2	EE(E)ELD-1		
3	EE(E)PIg./EC-3		
4	SE(E)EC-3		

Copy to:-

✓ 1. EE/ELD-1/DDA.

2. M/s N.K. Engineering Works.

3. M/s Bajaj Electricals.

4. M/s Goel Electricals.

5. Office copy.